

Smoke / CO Detector Replacement Code

14.4.8 Replacement of Smoke Alarms in One- and Two-Family Dwellings.

14.4.8.1 Unless otherwise recommended by the manufacturer's published instructions, single- and multiple-station smoke alarms installed in one- and two-family dwellings shall be replaced when they fail to respond to operability tests but shall not remain in service longer than 10 years from the date of manufacture.

14.4.8.2 Combination smoke/carbon monoxide alarms shall be replaced when the end-of-life signal activates or 10 years from the date of manufacture, whichever comes first.