



ROBERT W. SELTZER
CHIEF OF DEPARTMENT

SMITHFIELD FIRE DEPARTMENT

"To Help People"

HEADQUARTERS, STATION NO. 1
607 PUTNAM PIKE
SMITHFIELD, RHODE ISLAND 02828
www.smithfieldfire.com



TEL. (401) 949-1330
FAX (401) 949-1192

SITE PLAN REVIEW NOTICE

The Smithfield Fire Department conducts a site plan review separate from the building plan review.

A plan review of the proposed project shall be done to determine compliance with the Rhode Island Fire Laws and Rules Annotated (most current edition), NFPA 1 and all referenced standards, and the Smithfield Fire Prevention and Protection Ordinance.

The following must be shown on the site plan:

- An overview of the entire project (including a legal description)
 - Total lot size in square feet or acreage as appropriate, show phases where applicable. Plans shall be to scale.
 - Plat and Lot numbers
 - Street number and name as assigned by the Town of Smithfield
 - Building complex names
 - Existing and proposed elevation lines
 - North arrow
- A footprint plan of every building, including sheds, pavilions, guard sheds, etc.
 - Proposed entrances and exits
 - Loading docks and loading zones
 - Sprinkler and Standpipe Fire Department Connections and Post Indicator Valves
 - KNOX box/lock locations
 - Building setbacks from roadways and driveways. Show all buildings inside the lot and outside the lot within two hundred feet (200') of the lot lines.
- All fire suppression water supply sources in accordance with NFPA 1142 and applicable Town of Smithfield Ordinances.
 - Fire Hydrants (including water main location and size). Provide a catalog cut sheet on all fire hydrants. All fire hydrants shall have one (1) 4.5" and two (2) 2.5" discharge ports, Male, National Standard Threads.
 - Fire Department Connections – Two (2) 2.5" Female inlets (Siamese), National Standard Threads within 50' of a hydrant.
 - When connection to an approved water system is not possible, as determined by the AHJ, include above and underground water sources and fire pumps.

"We will be the most effective and proactive emergency service and disaster mitigation organization to make Smithfield the safest community to live, work and play."

- On and off street parking areas
 - Include islands, parking plan, ingress and egress to parking areas
 - Include gated, chained or limited access areas
 - Include plowed snow storage areas
 - Include the dimensions of travel lanes in the parking areas
 - Include Fire Department Access roads
- Fire lanes
 - Fire lanes shall be at least ten feet (10') from buildings, not less than twenty feet (20') of unobstructed width, able to withstand the live loads of fire apparatus, and have a minimum of thirteen feet six inches (13'6") of vertical clearance. Indicate fire lane paint striping and signage type and location on site plans.

Note: Fire lane signs must state "No Parking, Fire Lane, Tow Zone"

- All roadways, including widths, curbing and traffic control devices
 - Boulevard islands or separations where applicable
 - One-way traffic flows and all turning radius. Show maximum angles of all roads and fire lanes. Show the finish grade.
 - Turnarounds - Apparatus turnarounds shall accommodate our largest piece of apparatus and have an exterior minimum radius of 50' and interior radius of 22'
 - Dead-end fire department access roads in excess of 150 ft. in length shall be provided with approved provisions for the fire apparatus to turn around.
- All above ground and underground utilities including but not limited to:
 - Utility and light poles
 - Utility boxes
 - Dumpster locations or other outside refuse containers and storage.
- Prior to delivery of combustible materials and the start of any building construction, the water supply for fire protection, whether temporary or permanent, shall be acceptable to the AHJ and shall be available.
- Plan review fees are separate from the fees charged by the Building Official. A copy of the fee schedule can be provided upon request.